



NOTES:

1. METER SETTING NOT TO OBSTRUCTED IN ANYWAY.
2. ALL FITTINGS IN THE METER SPREAD SHALL BE BRASS I.P.T.
3. BACKFLOW PREVENTION DEVICE (RPZ) INSTALLED AND MAINTAINED BY OWNER. RPZ MUST BE TESTED ANNUALLY AND REPORT FORM MUST BE SUBMITTED TO MOON TOWNSHIP MUNICIPAL AUTHORITY.
4. RPZ MUST EITHER BE INSTALLED AHEAD OF DEDUCT METER, PIPED TO FLOOR DRAIN OR INSTALLED IMMEDIATELY OUTSIDE OF STRUCTURE IN A HOT BOX.
5. PROVIDE PROPER DRAIN AT METER SETTING.
6. DEDUCT METER CANNOT BE INSTALLED MORE THAN 5 FT. FROM FLOOR WITHOUT PRIOR AUTHORITY APPROVAL.
7. DEDUCT METER IS INSTALLED, OWNED AND MAINTAINED BY CUSTOMER. DEDUCT METER MUST BE AUTHORITY APPROVED.
8. DEDUCT METER SHALL BE EQUIPPED WITH AN EXTERIOR REMOTE READER. THIS REMOTE READER SHALL BE INSTALLED WITHIN ONE (1) FOOT OF THE EXISTING WATER METER REMOTE READER.
9. THE DEDUCT METER IS ONLY PERMITTED TO FEED OUTSIDE FIXTURES THAT DO NOT DRAIN TO THE SANITARY SEWER.
10. A STRAINER AND REGULATOR AHEAD OF THE DEDUCT METER IS ADVISABLE. CONSULT MANUFACTURER'S RECOMMENDATIONS.
11. DEDUCT METER SHALL BE EITHER SENSUS IPERL OR NEPTUNE MODEL T-10.

MOON TOWNSHIP MUNICIPAL AUTHORITY ALLEGHENY COUNTY PENNSYLVANIA		WATER DISTRIBUTION SYSTEM RESIDENTIAL DEDUCT METER
Not to scale	November 2013	Standard Detail SD-037