

WORKSHEET #2 FOR CWSS CWSS MATERIALS EVALUATION RESULT SUMMARY BY NUMBER OF SERVICE CONNECTIONS FOR EACH PLUMBING MATERIALS TYPE

Type of Structure	Type of Plumbing Material					
	Distribution System Piping		Interior Plumbing			
	LSLS	Lead Pipe	Copper Pipe with Lead Solder installed after 1982	Copper Pipe with Lead Solder installed before 1983		
Single Family Residences	0	0	Tier 1 279	Tier 3 4,775		
Multi-Family Residences	0	0	Tier 2 18	N/A		
Buildings	0	0	Tier 2 40	N/A		
TOTAL	0	0	337	4,775		

Tier Assignment Key for CWSS (to summarize tier 1, tier 2 and tier 3 totals)

Type of Structure	Type of Plumbing Material					
	Distribution System Piping		Interior Plumbing			
	LSLS	Lead Pipe	Copper Pipe with Lead Solder Installed After 1982	Copper Pipe with Lead Solder Installed Before 1983		
Single Family Residences	Tier 1	Tier 1	Tier 1	Tier 3		
Multi-Family Residences	Tier 2	Tier 2	Tier 2	Non-Tier		
Buildings	Tier 2	Tier 2	Tier 2	N/A *		

* Not applicable unless a SFR was converted to a BLDG, then Tier 3.